

FIRE SAFETY CERTIFICATE

No. 06/2025

Date : 31/01/2025

Certified that the **Swarajya Pratishthan's Tenant Genius International School, Gat No.24 (26+27/1) + (26+27/2), Waki Kh., Tal. Jamner Dist. Jalgaon (MH)** Comprised of Ground Floor + 1st Floor Owned / Occupied By **Swarajya Pratishthan's Tenant Genius International School** have Compiled with the Fire Prevention & Fire Safety Requirements in Accordance With Rule of Maharashtra Fire Prevention & Life Safety Act 2006 (Mah.III of 2007) Rules & Verified By The Officers Concerned Of Fire Service On 30 January 2025 in the Presence of **Mr. Manoj Patil, Manager, Genius International School, Gat No.24 (26+27/1) + (26+27/2), Waki Kh. (MH)** & that the Building / Premises is Fit for Occupancy Up to **VIIIth** With Effect From 31 January 2025 For Period Of **One Year** In Accordance With Rule & Subject to Compliance of specific conditions as appended.

Issued on 31 January 2025 at Fire Dept. of Malegaon (Dist. Nasik) by the undersigned.




(Pawar S. D.)

Chief Fire Officer

Malegaon Municipal Corporation

To,
The Manager,
Genius International School,
Gat No.24 (26+27/1) + (26+27/2),
Waki Kh., Tal. Jamner Dist. Jalgaon

ENDORSEMENT

THE NO OBJECTION CERTIFICATE ISSUED BY FIRE SERVICE STAND CANCELLED AN ANNULLED DUE TO.

NIL




(Pawar S. D.)

Chief Fire Officer

Malegaon Municipal Corporation



Malegaon Municipal Corporation

Fire & Emergency Services

Malegaon — 423203

Email : chief fireofficermmc@gmail.com



MFS/O.W./F./06/2025

Date : 31/01/2025

To,

Mr. Nitin Bhaurao Patil & 9 Other's C/o
Swarajya Pratishthan's

Tenant "Genius International School"

Gat No.24 (26+27/1) + (26+27/2), Waki Kh.,

Tal. Jamner Dist. Jalgaon

Sub : Grant of "Final No Objection Certificate" for your Group B,
Educational Building in the name of Swarajya Pratishthan's
Tenant "Genius International School", Gat No.24 (26+27/1) +
(26+27/2), Waki Kh., Tal. Jamner Dist. Jalgaon

Ref. : 1. This Office Provisional No Objection Certificate" No.

MFS/O.W./P./117/2024, Date : 07/10/2024

2. Certificate submitted by license agency M/s Rayon Protection
Pvt. Ltd., Jalgaon, vide there letter Ref No. : RPPL/FIRE/2024-
2025/211, Date : 09/10/2024

3. Inspection Date : 30/01/2025

This has reference to the above. This office has No Objection for (Final) fire approval for following proposed construction of Educational Building.

The Plot area of the said co. is 10900.00 Sq. Mtrs. and Proposed Built up area is 3944.78 Sq. Mtrs.

Since the fire fighting arrangements provided is installed by license agency i.e. M/s Rayon Protection Pvt. Ltd., Jalgaon, Dated : 09/10/2024 bearing license no. MFS/LA/RF-362/RD-344 issued by Directorate of Maharashtra fire service and has submitted certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety measure rules 2009 this office is issuing a "Final No Objection Certificate" for your following building having built up area admeasuring to 3944.78 Sq. Mtrs. The detail of the proposed construction is as under.

Sr. No.	Floor	Built up area in sq. mtrs.
1	Ground Floor	1972.09
2	1 st Floor	1972.09
Total Built up area in sq. mtrs.		3944.78
Height of the Building in Mtrs.		8.10

Statutory provisions under Maharashtra fire prevention and life safety measures act. 2006

1. Under **Section 3** of "Maharashtra Fire Prevention & Life Safety measure rules 2006" (here in after referred to as "Said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the fire and life safety measures adhering to national building code of India 2005 and as amended from time to time failing which it shall be treated as a violation of this said act.
2. It is presumed that you have completed the work adhering to the provisions under **Section 3** of the said act.
3. Under **Sub Section (3) of Section 3** It is responsibility of the owner of the occupier as the case may be shall furnish to the Chief Fire Officer or nominated Officer a certificate in prescribed form twice a year in the month of January & July regarding maintenance of Fire Prevention & Life Safety measure in good repair and efficient condition as specified in **Sub Section 1**
4. Under **Sub Section (4) of Section 3** No person shall tamper with alter remove or cause any injury or damage to any Fire Prevention & Life Safety equipment installed in any such building or part there of or instigate any other person to do so.

The Fire Fighting System provided by you in the premises as per Provisional No-Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The condition mention in the "Provisional No Objection Certificate" will remain **unchanged** the undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of activity or Transfer of plot or any future expansion, No Objection Certificate from this office is essential.

As per Maharashtra Fire Prevention and Life Safety Measures Act 2006 section 25 — Annexure — Part III, Mr. Nitin Bhaurao Patil & 9 Other's C/o Swarajya Pratishthan's Tenant "Genius International School" Gat No.24 (26+27/1) + (26+27/2), Waki Kh., Tal. Jamner Dist. Jalgaon has paid fire protection fund fees amounting to Rs.3,62,920/- (Three Lack Sixty Two Thousand Nine Hundred Twenty Rupees Only) vide UTR No. : IBKL240926486739, Dated : 26/09/2024



SANJAY
DADAJI
PAWAR

Digitally signed by
SANJAY DADAJI
PAWAR
Date: 2025.01.31
12:53:33 +05'30'

Chief Fire Officer
Malegaon Municipal Corporation

Copy submitted to:

1. The Director, MFS, Mumbai for information please

===== Ends Here =====



Malegaon Municipal Corporation

Fire & Emergency Services, Malegaon

Email : chieffireofficermmc@gmail.com



MFS/O.W./P./117/2024

Date : 07/10/2024

To,

Mr. Nitin Bhaurao Patil & 9 Other's C/o

Swarajya Pratishthan's

Tenant "Genius International School"

Gat No.24 (26+27/1) + (26+27/2), Waki Kh.,

Tal. Jamner Dist. Jalgaon

Sub : NOC stipulating fire protection and fire fighting requirements for your

Proposed construction of Genius International School, Gat No.24 (26+27/1) + (26+27/2), Waki Kh., Tal. Jamner Dist. Jalgaon

Ref. : Application No. MFS/I.W./109/2024, Date : 24/09/2024

This is a proposal for construction of Group B, Educational Building, Genius International School as detailed given below. Total Plot Area is 10900.00 Sq. Mtrs. The said of building consists of Ground Floor + 1st Floor and height of the building is 8.10 mtrs. The detail of the proposed construction is as under.


Sr. No.	Floor	Built up area in sq. mtrs.
1	Ground Floor	1972.09
2	1 st Floor	1972.09
Total Built up area in sq. mtrs.		3944.78

The site abuts on 12.00 mtrs. wide road on **South Side**. The open space around the building are as follows:

Direction	Building line to Plot Boundary in mtrs.
East	24.03
West	6.00
North	6.00
South	10.04


This NOC is valid subject to fulfillment of the following conditions provisions of Maharashtra Fire Prevention & Life Safety measure rules 2006.

- Under **Section 3** of "Maharashtra Fire Prevention & Life Safety Measure Rules 2006" (here in after referred to as said act) the applicant (developer, owner, occupier by whatever name called) shall comply with all the fire and life safety measures adhering to national building code of India 2016 and as amended from time to time failing which it shall be treated as a violation of the said act.
- As per the provisions as **under :- 10** of the said act no person other than the license agency shall carry out the work of providing fire prevention and life safety measures or performing such



other related activities required to be carried out in any place or building or part thereof provided that.

- A) If the director MFS is satisfied that, for any reason, to be recorded in writing, the owner or Occupier is not able to carry out the fire prevention and life safety measures in any such place or Building or part thereof through a licensed agency. He may authorize any person or persons shall Be deemed to be carried out by licensed agency.
- B) No licensed agency or any other person claiming to be such Licensed Agency shall give a Certificate under **sub section (3) of section 3** regarding the compliance of the fire prevention & life safety measures or maintenance thereof in good repair & efficient condition, without there Being actual such compliance or maintenance. The names of the licensed agencies approved by Directorate Maharashtra is available in our website www.mahafireservice.gov.in
3. Though certain conditions are stipulated from the said act and the National Building Code of India, it is obligatory on part of the applicant that is developer, builder, occupier, owner, tenant by what so ever named called to abide with the provisions of said act.
 4. The plans of the building should be approved by the concern competent authority.
 5. The occupancy certificate should be obtained from the competent authority. **The O.C. shall be Issued subject to final no objection certificate from this department.**
 6. **Proper roads in the premises should be provided for easy mobility of the fire brigade appliance as per the guidelines given in NBC 2016 should be kept free from obstructions all the time. The load bearing capacity of internal roads must be minimum 45 tones. The width of the road shall not be less than 6 mtrs. For easy maneuver competent authority of the building proposal department.**
 7. **Inspection of fire fighting installation will be carry out by the representative of this fire department during installation of the fire fighting system.**
 8. All portable fire fighting equipments installed at various locations as per local hazard such as Co2-DCP, Foam, Fire Buckets should be strictly confirming to relevant IS specification. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency. The monitoring mechanism for all firefighting equipment should be designed and implemented. **The guidelines should be followed based on IS 15683 & IS 2190 code of practice for selection, installation and maintenance of portable first aid fire extinguishers.**
 9. All the fire fighting equipments shall be well maintained & should be easily accessible in case of emergency.
 10. Emergency telephone numbers like "Police", "Fire Brigade", "Hospital", "Doctors & Responsible Persons" should be displayed in security cabin and production building.
 11. It shall be insured that security staff and every employee of the co. are trained in handling fire fighting equipment's & fire fighting.
 12. **"Fire Extinguisher" "Fire Bucket" "Danger" "No Smoking" caution boards should be displayed at the places physically shown & the caution boards should be easily visible and as per the guidelines given in IS : 9457, IS : 12349 and IS : 12407.**
 13. **The house keeping shall be well maintained within the entire premises.**
 14. All electrical appliances / fitting sand fixtures should be strictly flame proof.

- 
15. The fire exit drill or evacuation drill should be plan and instruction should be given to the staff minimum **four times in a year** and drill should be carried out **twice in a year**.
 16. **"On site" & "Off side"** emergency plan / **evacuation plan** shall be prepared & mock drills should be conducted twice a year & instructions to every employee shall be given once in three months.
 17. In future if the developer intends to go for expansion, alteration, modification of any building an approval of fire department must be obtained before commencing proposed construction.
 18. Stability certificate to all buildings shall be obtained from architect or competent person as per the rule 3-A of Maharashtra Factories Rules 1963.
 19. The height & other clearances / approvals must be obtained from local "Civil Aviation Department" in necessary.
 20. All necessary approvals required from government / planning / special planning authority shall be obtained, as applicable.

REQUIREMENT AND PROVISION: - The following fire protection system is required for the fire safety of the building: - (As per requirement of Table 7 of Part 4)

Sr. No.	Fire Fighting Installation	Requirements	Provision	Remarks
1	Portable Fire Extinguishers	Required		IS: 2190 & 15683
2	Hose Reel	Required	In all staircases	On each floor in the Staircase landing for Fire Fighting. The first aid hose reel shall be connected directly to riser/down comer main and diameter of the hose reel shall not be less than 19 mm confirming to IS 884:1985
3	Terrace Level Tank	Required 10,000 Ltrs.		On Each Terrace
4	Fire Pump	1 Nos. — 450 LPM Electric Driven (Booster Pump on Terrace)		Fire Fighting pumps shall be well maintained. Booster pump should be provided on each terrace.
5	Fire Brigade Connection — For static water tank and for hydrant system	Required at the Main Gate		



6	Sign indicators for all fire safety, safe evacuation of occupants in case of emergency signs	Required at Prominent Places.	Sign indicators should be provided at prominent places as per the guidelines given in IS:9457 for Safety colour and Safety IS:12349 for Fire Protection Safety Signs IS:12407 for Graphics symbols for Fire Protection Plan.
7	Fire Doors	Required	Fire Doors of 2 hrs. Fire Resistance Rating should be provided at the entrance of the staircase. Certification from the Competent Authority.
8	Emergency lights	Required	Required at prominent places
9	Auto D.G. Backup	Required	Required for all fire safety systems

Note : Fixed fire fighting installations such as risers, hydrant connections, hose reels etc. shall be provided in separate shaft having opening at floor level with glass cabinet having locking arrangement to avoid the ft. and damage.

GUIDELINES FOR INTERNAL STAIRWAYS as per NBC 2016

Ref NBC part 4, clause No. 4.4.2.4.3.2

EXTERNAL STAIRCASE OR FIRE ESCAPE STAIRCASE:

Ref NBC part 4, clause No. 4.4.2.4.3.4

STAIRCASE DESIGN REQUIREMENTS:

Ref NBC part 4, clause No. 4.4.2.4.3.1

FIRE LIFT:

Ref part 8, Section 5, Clause 7

LIFT ENCLOSURES:

Ref Part 8, Section 5, Clause 7

GUIDELINES FOR REFUGE AREA

Ref E — 4 of NBC Part 4

PODIUM

Ref Part 3, Clause 4.6.1

Special requirement such as LPG Storage, Kitchen, Raw Material etc.
(as per the requirements)

SERVICE DUCTS AND SHAFTS

Ref Part 4, Clause 3.4.5.4



ELECTRICAL SERVICES

Ref Part 4, Clause 3.4.6

Access:

Two entrance gates each of width not less than 4.50 mtrs. and height clearance not less than 4.50 mtrs. Shall be provided.

COURTYARDS:

- i) The courtyards on all sides of the building shall be paved suitably to bear the load of fire engines weighing up to 45 m. tones and shall be flushed to road level.
- ii) The courtyards shall be in one plane.

PORTABLE FIRE EXTINGUISHERS:

- a. Two dry chemical powder (ABC) type fire extinguisher of 4 kgs. Capacity and Co2 type extinguisher of 4.5 kg. having ISI certification mark and two buckets filled with dry, clean and shall be kept in electric meter room as well as lift machine room of each building.
- b. Adequate Nos. of Dry Chemical Powder (ABC) type fire extinguishers each of 4 kg. Capacity having ISI (15682 & 2190) certification mark shall be kept at parking area equally distributed places in stilts.

TERRACE DOOR:

- i) The top half portion of the doors shall be provided with louvers.
- ii) The latch lock shall be installed from the terrace side at the height of not more than 1 mtrs.
- iii) The glass front of 6 inch diameter with the breakable glass shall be provided just above the latch lock, so as to open the latch in case of an emergency by breaking the glass.

SIGNAGESS:

Self glowing / fluorescent EXIT signs in green color shall be provided showing the means of escape for the entire building.

In addition to the above, all provision under the National Building Code of India 2016 shall be strictly adhered, also if any change in activity or proposed expansion or subletting of Plot, NOC from this department is essential.

This is a "Provisional No Objection Certificate" after compliance with above mentioned recommendations / conditions, inspection of the fire prevention & protection systems provided by you will be carried out by this department & after satisfactory performance of the system "Final No Objection Certificate" will be issued.

The undersigned reserves right to amend any additional recommendations deemed fit during the final inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company.

As per Maharashtra Fire Prevention and Life Safety Measures Act 2006 section 25 — Annexure — Part III, Mr. Nitin Bhaurao Patil & 9 Other's C/o Swarajya Pratishthan's Tenant "Genius International School" Gat No.24 (26+27/1) + (26+27/2), Waki Kh., Tal. Jamner Dist. Jalgaon has paid fire protection fund fees amounting to Rs.3,62,920/- (Three Lack Sixty Two Thousand Nine Hundred Twenty Rupees Only) vide UTR No. : IBKL240926486739, Dated : 26/09/2024

However, Town Planning is requested to verify the total built up area and inform this department for the purpose of levying additional capitation fee.



**SANJAY
DADAJI
PAWAR**

Digitally signed
by SANJAY
DADAJI PAWAR
Date: 2024.10.07
13:28:10 +05'30'

Chief Fire Officer
Malegaon Municipal Corporation

Copy submitted to:

1. The Director, MFS, Mumbai for information, please

===== Ends Here =====